

D.B. WETT INSPECTIONS

INSPECTION REPORT

Solid Fuel Space Heater and Factory Chimney
250 Angus point

Inspection completed on September 29 2007

Observations made at 250 angus point. A certified solid fuel space heater vented to a certified factory chimney.

The appliance does comply with W.E.T.T. standards.

The chimney appears to be a certified factory stainless steel chimney that does comply with W.E.T.T. STANDARDS

No flammable gases or vapor ,combustible dust ,fibers, or corrosive atmosphere was observed.

The inspection was made of all readily available components that are visible. Excluded are all latent and concealed defects and deficiencies in walls and other unseen situations.

Donald Bruce.

Certified W.E.T.T. Inspector #7669

